

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Application of Southern California Edison Company
(U 338-E) for Approval of the Results of Its 2013
Local Capacity Requirements Request for Offers for
the Moorpark Sub-Area.

Application 14-11-016
(Filed November 26, 2014)

**TESTIMONY OF ROBERT PERRY
DIRECTOR OF ENERGY RESEARCH OF THE
WORLD BUSINESS ACADEMY**

Laurence G. Chaset
KEYES, FOX & WIEDMAN LLP
436 14th Street, Suite 1305
Oakland, CA 94612
E-mail: lchaset@keyesandfox.com
Phone: (510) 314-8385
Attorney for World Business Academy

Date: April 8, 2015

TABLE OF CONTENTS

	<u>Page</u>
I. INTRODUCTION	1
II. SCE'S PROPOSED REFURBISHMENT OF THE ELLWOOD PLANT DOES NOT MEET THE IDENTIFIED LCR NEED	2
III. SCE'S PROPOSED REFURBISHMENT OF THE ELLWOOD PLANT WILL POSE SERIOUS ADVERSE ENVIRONMENTAL HAZARDS	10
IV. THE DISTRIBUTED ALTERNATIVE PROJECT THAT THE COMMISSION SHOULD DIRECT SCE TO PROCURE	12
V. THE ACADEMY'S DISTRIBUTED ALTERNATIVE PROJECT IS MORE COST EFFECTIVE THAN SCE'S PROPOSED GAS TURBINES	21
VI. OTHER ENVIRONMENTAL BENEFITS OF THE ACADEMY'S DISTRIBUTED ALTERNATIVE PROJECT	28

ATTACHMENT A

***CURRICULUM VITAE* OF ROBERT PERRY
DIRECTOR OF ENERGY RESEARCH OF THE
WORLD BUSINESS ACADEMY**

ATTACHMENT B

TABLES

ATTACHMENT C

**AERIAL PHOTOS AND ESTIMATES
REGARDING SOLAR PV CAPACITY**

ATTACHMENT D

**AERIAL PHOTOS AND ESTIMATES
REGARDING POTENTIAL COMMUNITY SOLAR PROJECTS**

TESTIMONY OF ROBERT PERRY
DIRECTOR OF ENERGY RESEARCH OF THE
WORLD BUSINESS ACADEMY

I. INTRODUCTION

Q: Please state your name and business address for the record.

A: Robert Perry. 2020 Alameda Padre Serra, Suite 135, Santa Barbara, CA 93103.

Q: What is your academic background and professional qualifications?

A: Attachment A to this testimony contains my Curriculum Vitae, which describes my academic background and professional qualifications.

Q: What is the purpose of your testimony?

A: The World Business Academy ("Academy") has proposed, as a superior alternative to the project that the Southern California Edison Company ("SCE") has submitted for Commission approval in this proceeding: a hybrid power generation and storage system relying on new, local solar PV generation along with fuel cell and battery technologies. This hybrid system would be the first stage in developing a community-wide energy "cloud" of networked microgrids developed at the substation level.

The purpose of my testimony is to compare and contrast (i) the environmental, operational and economic costs and benefits of installing the Academy's proposed hybrid system against (ii) SCE's proposed project within the context of the inevitable failure of the solitary high-voltage transmission line that provides most, if not all, power for the Santa Barbara Energy Needs Area ("ENA"), which includes but is not limited to the cities of Santa Barbara, Goleta, Montecito,

1 Summerland and Carpinteria.¹ Based on this analysis, my testimony will
2 demonstrate that by taking certain environmental, operational and economic
3 externalities into account, the overall **costs** of developing such distributed
4 generation and storage facilities will be **lower** than the actual costs of SCE's
5 proposed project and that the overall **benefits** of the Academy's proposed
6 alternative will be **greater** than the benefits from SCE's proposed project.
7

8 **II. SCE'S PROPOSED REFURBISHMENT OF THE ELLWOOD PLANT**
9 **DOES NOT MEET THE IDENTIFIED LCR NEED**
10

11 **Q: Do you believe that Commission approval of the results of SCE's 2013 LCR**
12 **RFO for the Moorpark sub-area would enhance the safe and reliable**
13 **operation of SCE's electrical service?**

14 **A:** In a word, NO. I agree with the Testimony of Rinaldo S. Brutoco, the
15 Academy's President, which is being submitted simultaneously with my
16 Testimony, that the reliability enhancements from the proposed refurbishment of
17 the Ellwood facility are illusory, and will fail to provide ratepayers with
18 sufficient energy to achieve near 100% operational reliability, even when
19 combined with net available capacity from sub-transmission lines under
20 development as a backstop against the failure of the compromised high-voltage
21 transmission lines currently providing power to the region.²
22

23 In its Response filed under in proceeding, SCE states that the Ellwood
24 Refurbishment Project is not part of the LCR procurement (*italics added*):
25

¹ As disclosed by SCE in A.12-10-018, [Application of Southern California Edison Company \(U338E\) for a Permit to Construct Electrical Facilities with Voltages between 50 kV and 200 kV: Santa Barbara County Reliability Project](#), pp. 2-7. *See also*, Testimony of Rinaldo S. Brutoco, President of the World Business Academy, pp. 4-9, filed concurrently herewith.

² A.12-10-018, at pp. 4-5.

1 "SCE is not proposing to count the 54 MW Ellwood Refurbishment
2 project toward its LCR procurement authorization for the Moorpark
3 sub-area. This unit was assumed to be online in CAISO's LCR need
4 assessment. However, in the absence of a long-term PPA, *the*
5 *likelihood of a permanent retirement of this resource, which plays an*
6 *important role for system reliability, would significantly increase,*
7 *which in turn would result in additional and higher LCR need in the*
8 *Moorpark sub-area. The proposed Ellwood Refurbishment PPA*
9 *avoids the need for SCE to develop additional new resources in*
10 *excess of SCE's current LCR procurement authorization for the*
11 *Moorpark sub-area.*

12
13 "Refurbishment of the Ellwood facility is necessary to enhance
14 certain operational characteristics of the unit to maintain system
15 reliability in the Goleta portion of the Moorpark sub-area. As
16 indicated in SCE's LCR Procurement Plan, approved by the Energy
17 Division on September 4, 2013, *reliable resources in the Goleta*
18 *area are needed to maintain system reliability for local communities*
19 *in the area.*"³

20
21 A footnote in the above excerpt references SCE's Track 1 Procurement Plan,
22 where the gravity of the impact from the loss of the high-voltage transmission
23 lines is fully explained:

24
25 "As can be seen from Figure II-3, the Goleta substation area is
26 served radially from Santa Clara substation by two 230 kV lines,

³ See, [Southern California Edison Company's \(U 338-E\) Response to Protests to Its Application for Approval of the Results of Its 2013 Local Capacity Requirements Request for Offers for the Moorpark Sub-Area](#), p. 7.

1 Santa Clara-Goleta No. 1 and No.2. *The two Santa Clara-Goleta 230*
2 *kV lines are co-located on a single tower corridor through rugged*
3 *mountainous terrain in a wooded area that is subject to natural*
4 *hazards including soil erosion and wildfires.* If an outage occurred
5 on the two Santa Clara-Goleta 230 kV lines, SCE can serve
6 approximately two-thirds of the peak loads served by Goleta
7 substation by being transferred to an adjacent 66 kV system once a
8 proposed upgrade to that system that presently awaiting CPUC
9 approval is completed. [A footnote appended to this sentence reads
10 as follows: *Before completion of the upgrade to the 66 kV system*
11 *currently awaiting CPUC approval, SCE can only serve one-third of*
12 *peak load by transferred the load to an adjacent 66 kV system, if an*
13 *outage occurred on the two Santa Clara-Goleta 230 kV lines.*]
14 However, *the time period to restore full service to load served by*
15 *Goleta substation could be significant.* Due to the rugged terrain,
16 loss of the Santa Clara-Goleta lines due to environmental hazards
17 could result in *rolling blackouts in this area for an extended period.*
18 *There is significant value to the local communities in seeking*
19 *generation sited in this area."*⁴

20
21 It appears from SCE's foregoing statements that the true purpose for
22 "refurbishing" this aging turbine plant is not to provide peaking services to the
23 Moorpark Sub-Area (which services would seem to be rarely needed, given the
24 extremely limited output of the Ellwood plant in recent years), but rather to act as
25 a "fail-safe" against the impending failure of the current compromised high-
26 voltage transmission line. Furthermore, should the proposed 54 MW peaker
27 plant in the Ellwood neighborhood be completed, its capacity would not fully

⁴ See, [Track 1 Procurement Plan of Southern California Edison Company Submitted Pursuant to Energy Division Pursuant to D.13-02-015](#), p. 16.

1 cover the energy shortage resulting from the failure of the existing transmission
2 line, when power is rerouted through the sub-transmission lines connecting the
3 Moorpark Sub-Area grid to the opposite southern end of the Santa Barbara ENA
4 at the Carpinteria Substation.

5
6 The CAISO's 2014-2015 ISO Transmission Plan, dated March 27, 2015,
7 forecasts the 2016 summer peak load for the Goleta Substation at 321 MW.⁵
8 However, prior to completion of the currently proposed sub-transmission
9 upgrade, the Santa Barbara ENA faces a shortage of 66% of its peak load, or 214
10 MW, in the event of a transmission failure. Even if the proposed upgrade is
11 completed, the ENA is still short 33% of peak load, or 107 MW. Therefore,
12 under the most optimal scenario described above, the proposed peaker plant
13 would only partially mitigate a foreseeable catastrophe, and even with the
14 proposed refurbishment of the Ellwood plant and completion of the proposed
15 sub-transmission line upgrade, energy delivery services by SCE to the Santa
16 Barbara ENA in the event of a primary transmission line failure could in no
17 manner be described as “reliable.”

18
19 With regard to safety, the circumstances described in the previous paragraphs
20 would also require changing the function of the “peaker” plant, required to
21 operate only a few hours each day, to more of a baseload role, such that the
22 Ellwood plant would be required to be constantly operating to cover a portion of
23 the 33-66% power shortage for most of the day and well into the night. Under
24 this scenario, the emissions of carbon and hazardous fine particulates from the
25 refurbished Ellwood plant would likely triple or quadruple, and that plant would
26 likely be operating during school hours at Ellwood Elementary, which is situated
27 less than 1,000 feet from the plant site.

⁵ See, [CAISO 2014-2015 ISO Transmission Plan](#), p. 122.

1
2 As for sound pollution, the Academy has yet not found relevant data concerning
3 the noise emissions from this plant, but it is a well-established fact that even
4 when enclosed, such jet engine turbine plants have a loud acoustic signature.
5

6 **Q: Are the results of SCE's 2013 LCR RFO for the Moorpark sub-area a**
7 **reasonable means to meet the 215 to 290 MW of identified LCR need**
8 **determined by D.13-02-015?**

9 **A:** The procurement proposed in this proceeding is not reasonable in that (i) under
10 the best circumstances, the proposed peaker plant only serves the energy needs of
11 the larger Moorpark Sub-Area at the expense of adjacent Ellwood residents; (ii)
12 in the event of a transmission failure, the plant's 54 MW capacity will be
13 insufficient to cover the shortage resulting from rerouting power to the 66 kV
14 sub-transmission lines; and (iii) in the event of a transmission failure, the plant
15 will operate far outside its intended parameters, subjecting the primarily
16 residential area, and particularly the school children attending the adjacent
17 elementary school located less than 1,000 feet from the facility site, to vastly
18 higher emissions of hazardous particulates which have been known to cause
19 major adverse medical conditions, including cancer.
20

21 Although the Commission's Track 1 Decision in D.13-02-015 does not mandate
22 the procurement of any particular type of resource for the Moorpark Sub-Area,
23 there are numerous references in that Decision to the preference for preferred
24 resources as specified in the Loading Order (*italics added*):
25

26 "SCE is also authorized to procure between 215 and 290 MW of the
27 Moorpark sub-area of the Big Creek/Ventura local reliability area.
28 *The LCRs require resources be located in a specific transmission-*
29 *constrained area in order to ensure adequate available electrical*

1 *capacity to meet peak demand, and ensure the safety and reliability*
2 *of the local electrical grid.*

3 . . .

4 "The long-term LCRs are expected to result from the retirement of
5 thousands of MW from current once-through cooling generators due
6 to compliance with State Water Quality Control Board regulations.
7 *We anticipate that much of the additional LCR need currently*
8 *forecast by the California Independent System Operator can be filled*
9 *by preferred resources, either through procurement of capacity or*
10 *reduction in demand.* Preferred resources include energy efficiency,
11 demand response, and distributed generation including combined
12 heat and power. Energy storage resources may also be available.

13
14 "In the next long-term procurement proceeding, expected to
15 commence in 2014, we will evaluate whether there are additional
16 LCR needs for local reliability areas in California."

17 . . .

18 "SCE is directed to begin a solicitation process to procure authorized
19 LCR resources. The first step is a plan to issue one or more Request
20 for Offers and/or to enter into cost-of-service contracts per Assembly
21 Bill 1576 (Stats 2005, ch. 374). *SCE should also actively pursue*
22 *locally-targeted and cost-effective preferred resources. SCE's*
23 *procurement plan shall be consistent to the extent possible with the*
24 *multi-agency Energy Action Plan, which places cost-effective energy*
25 *efficiency and demand response resources first in the Loading*
26 *Order, followed by renewable resources and then fossil-fuel*

1 *resources. Energy storage resources should be considered along*
2 *with preferred resources.*⁶

3 . . .

4 "As part of our review of SCE's procurement plan, and when
5 considering SCE's procurement application, *we will require SCE to*
6 *show that it has done everything it could to obtain cost-effective*
7 *demand-side resources which can reduce the LCR need, and cost-*
8 *effective preferred resources and energy storage resources to meet*
9 *LCR needs.* This task includes efforts already underway and
10 approved in other Commission proceedings, with *an eye to focusing*
11 *such efforts in the specific local geographic areas where LCR needs*
12 *exist.*"⁷

13
14 The Commission even takes notice of SCE's acknowledgement that new
15 technologies embodied in preferred resources can better serve the Moorpark
16 Sub-Area (footnotes omitted, *italics* added):

17
18 "SCE recommends deferring authorization for procuring additional
19 local capacity in the Big Creek/Ventura local area until the next
20 LTPP cycle (expected to commence in 2014). SCE contends that
21 barriers to construction of new LCR generation is not as difficult in
22 the Big Creek/Ventura local area as in the LA basin local area,
23 because "this area does not have as many, or as stringent, siting
24 restrictions as the LA basin." *SCE further argues that newer*
25 *technology of various sizes is more likely to be the replacement*

⁶ [D.13-02-015](#), Decision Authorizing Long-Term Procurement for Local Capacity Requirements, Summary, pp. 2-3.

⁷ [D.13-02-015](#), p. 78.

1 *generation in the Moorpark sub-area, which may be able to be built*
2 *in 5 to 7 years.”⁸*
3

4 The requirement to locate resources “in a specific transmission-constrained
5 area in order to ensure adequate available electrical capacity to meet peak
6 demand, and ensure the safety and reliability of the local electrical grid”
7 seems to prioritize the needs of the residents within the “transmission-
8 constrained area” over the broader requirements of the Moorpark Sub-Area.
9 The focus on procuring demand-side resources, preferred resources and
10 energy storage also places a burden on SCE to look for a “better fit” for the
11 Santa Barbara ENA. Even SCE acknowledges these circumstances,
12 arguing that “newer technology of various sizes is more likely to be the
13 replacement generation in the Moorpark sub-area.”⁹ In this light, installing
14 a 54 MW peaker plant that is likely to exceed its operating parameters for
15 an extended period of time during a foreseeable emergency clearly does not
16 qualify as a “best fit” solution for the Santa Barbara ENA.
17

18 **Q: Is the 54 MW Ellwood Refurbishment project appropriate for the**
19 **Commission to consider in this proceeding and, if so, is the contract**
20 **reasonable?**

21 **A:** The 54 MW Ellwood Refurbishment project is neither an appropriate nor a
22 reasonable project for the Commission to approve, as this proposed facility is not
23 the “best fit” for the densely populated and extremely transmission-constrained
24 Santa Barbara ENA, which is already subject to a potentially catastrophic failure
25 of its high-voltage transmission system. Moreover, this proposed project is
26 located in the rapidly developing Ellwood residential area of Goleta, less than
27 1,000 feet away from the local elementary school. There are also large

⁸ [D.13-02-015](#), pp. 68-69.

⁹ *Id.*

1 residential tracts located on both sides of the plant site that would be adversely
2 impacted should the plant need to operate longer hours than originally intended
3 due to the transmission line failure.

4
5 **Q: Is the contract with NRG California South LP, for a 0.5 MW storage**
6 **project, reasonable?**

7 **A:** For the near term, the small capacity of the proposed storage project is
8 reasonable in that there has not been much penetration to date by intermittent
9 renewable resources in the Santa Barbara ENA. However, the scale of
10 penetration by renewable resources in the Santa Barbara ENA is expected to
11 ramp up dramatically as area communities become aware of the fragile state of
12 the local transmission and distribution grid. Electricity customers in this area
13 will therefore soon be demanding a more reliable and resilient distributed
14 solution. This significant increase in demand for renewable generation will, in
15 turn, require much larger procurements of storage and distributed generation for
16 the Santa Barbara ENA in subsequent LCR proceedings.

17
18 **III. SCE'S PROPOSED REFURBISHMENT OF THE ELLWOOD PLANT**
19 **WILL POSE SERIOUS ADVERSE ENVIRONMENTAL HAZARDS**
20

21 **Q: Are the LCR RFO contracts consistent with the Commission's Emissions**
22 **Performance Standards ("EPS")?**

23 **A:** No. In the event of a transmission failure as described above, the plant's
24 proposed operation as a peaker facility, scheduled to run only a few hours a day
25 to supply extra energy during peak load periods, would be completely
26 undermined, as continuous operation during the foreseeable transmission failure
27 would inevitably be required to make up for a portion of the shortfall.
28

1 Peaker plants are designed to quickly deliver power for short periods and their
2 high emissions profile requires them to operate only a few hours a day in order to
3 remain within EPS requirements. As the impending transmission failure would
4 be deemed an “emergency,” SCE would certainly apply for an exemption from
5 EPS requirements until either the high-voltage transmission lines are repaired (at
6 an extremely high cost), or local generation and storage facilities are developed.
7 Ironically, it is just those types of facilities that the Academy is currently
8 proposing to implement on a proactive basis in lieu of the proposed peaker plant.
9

10 The fuel cell and battery technologies that would comprise these facilities are
11 wholly compliant with all EPS standards, as they have an extremely low
12 emissions footprint and are capable of operating free of all carbon and fine
13 particulate emissions.
14

15 **Q: Should the Commission approve these contracts prior to completion and a**
16 **final decision by the California Energy Commission ("CEC") on the**
17 **required California Environmental Quality Act ("CEQA") review?**

18 **A:** Given the likelihood that both of the peaker plants proposed for approval in this
19 Application will operate much longer than anticipated, with attendant carbon and
20 fine particulate emissions, the Academy urges the Commission to delay approval
21 of the contracts pending CEC CEQA approval and to use the interim period to
22 pursue a more distributed and resilient solution. Moreover, the CEQA review of
23 the proposed 54 MW Ellwood peaker plant should unquestionably include a
24 careful consideration of likelihood that there will be serious issues with the
25 primary transmission lines, which will require much longer, if not continuous,
26 operation of the plant during any interim period during which those lines are
27 being repaired.
28

1 **IV. THE DISTRIBUTED ALTERNATIVE PROJECT THAT THE**
2 **COMMISSION SHOULD DIRECT SCE TO PROCURE**
3

4 **Q: What would be a more appropriate and reasonable procurement for the**
5 **Commission to consider in this proceeding?**

6 **A:** A significantly more reasonable and appropriate procurement solution would be
7 to reallocate a substantial portion of the total 316 MW of capacity authorized
8 pursuant to the Commission's Track 1 Decision for development within the Santa
9 Barbara ENA to make up for the imminent energy shortage inherent in SCE's
10 current proposal. All such reallocated resources can and should be Preferred
11 Resources. A mix of clean, distributed resources would be far superior to
12 replacing an old gas turbine plant with a "new" turbine combustion facility for
13 the next 25-30 years. (Indeed, there is a high likelihood that increasingly
14 stringent emission standards will render such a "new" turbine combustion facility
15 a "stranded asset" long before the end of its useful life.)
16

17 The Academy's proposed Distributed Alternative Project that the Commission
18 should direct SCE to procure instead of the two peaker plants proposed in the
19 Application under review would include:
20

21 Solar PV (Distributed Generation). The foundation for any distributed energy
22 system is locally sited generation. It is essential that the latent energy capacity of
23 solar PV within the Santa Barbara ENA be developed to the fullest extent
24 possible, with a concurrent development of storage capacity based on projected
25 solar PV penetration. As a result of its unique geography, the entire Santa
26 Barbara ENA is south-facing, providing ample opportunities to install solar PV
27 in areas exposed to direct sunlight for extended periods each day.
28

1 To date, the Santa Barbara ENA has a very little installed solar PV systems, and
2 there is plentiful commercial/industrial roof space on which to mount large PV
3 systems for an aggregate multi-megawatt capacity. Attached as Exhibit C to this
4 Testimony are aerial digital photographs¹⁰ of prime rooftop locations within the
5 Santa Barbara ENA that are within close proximity to substations. As is evident
6 from the attached aerials, the conversion of this fallow roof and parking lot space
7 is capable of generating between 50-100 MW of daily capacity for direct use
8 during the daytime or for storage for later use off-peak.
9

10 Additionally, undeveloped fields on south-facing hillsides adjacent to substations
11 can be developed as community solar projects, where investors and local citizens
12 can own equity shares of dedicated solar PV generation without having to
13 personally own PV systems, and receive dividends on their equity through a
14 credit reduction on their utility bill. There are south-facing hillsides, located
15 within proximity to substations, from the San Marcos Pass to Goleta and as far
16 north as Gaviota, to add at least another 50-100 MW of capacity, if needed.
17

18 Strategic development of existing rooftops, public and private parking areas and
19 south-facing hillsides will create enough renewable energy generation within the
20 Santa Barbara ENA to continuously power a properly managed microgrid
21 distribution system. With properly distributed and located generation, storage
22 and electrolysis facilities, there should be no concerns regarding grid instability
23 from over-generation, as the microgrid system will incorporate an established
24 hierarchy for the application of any surplus energy: first to serve microgrid load
25 and maximize local storage capacity; second, for transmission to the outer
26 Moorpark Sub-Area if needed; and finally, for the electrolysis of water into
27 hydrogen either for long-term storage or for sale to hydrogen fuel cell ("HFC")

¹⁰ These digital aerials were created using Google Earth software.

1 vehicle refueling stations as a secondary revenue source. With properly allocated
2 resources, there should be no scenario where surplus renewable energy would
3 have to be wasted through needless curtailment measures.

4
5 Hybrid Fuel Cell-Battery Plants Strategically Located at Wastewater, Landfill
6 and Desalination Sites. To the extent possible, these plants would utilize fuel
7 cell technology to provide essentially baseload, carbon-neutral power using
8 available biogas feedstock from anaerobic digesters at municipal wastewater and
9 landfill sites, while an appropriately sized battery component would provide
10 ramping, peak shaving and ancillary services to the adjacent area. The hybrid
11 plant servicing the city's soon-to-be-activated desalination plant would play a
12 particularly unique role within the Santa Barbara ENA: connected to both the
13 plant and the distribution grid, this facility would be available on a continuous
14 standby basis to provide emergency grid support services by instantly diverting
15 all or a portion of its capacity from its baseload function serving the desalination
16 plant to other areas in order to meet peak load needs at either the distribution or
17 transmission grid levels when the primary solar PV generation is not available, or
18 in case of a transmission line failure, as described above.

19
20 Such a strategic position within the microgrid will effectively enable a baseload
21 energy source also to offer dispatchable energy via switchable grid service
22 functions. Furthermore, because fuel cells are modular, switching capabilities
23 would be assigned on a per unit basis, allowing for immediate or gradual
24 ramping during the early morning and late afternoon/early evening hours as
25 shown in the by now well-known "duck curve" graph.¹¹

¹¹ California ISO, "[Fast Facts: What the Duck Curve Tells Us about Managing a Green Grid](#)," 2013.

1 Flow Batteries (Utility-Scale Energy Storage) at Substation Locations. These
2 utility-scale installations would be located adjacent to substations and calibrated
3 to store enough excess solar energy generated during peak periods for
4 transitional ramping needs, off-peak generation at night and for ancillary services
5 such as phase and voltage regulation to enhance grid reliability.¹² The unique
6 characteristic of flow batteries is the capacity to hold large volumes of charged,
7 non-toxic¹³ electrolyte in underground tanks as stored energy, and then to
8 discharge that energy over many hours, with the only limiting factor being the
9 size of the tanks storing the electrolyte in either a charged or discharged state.

10
11 For example, a flow battery facility with a 5 MW capacity connected to
12 underground tanks holding 50 MW of charged electrolyte could provide energy
13 at full capacity for 10 hours, effectively bridging the nighttime portion of the 24-
14 hour diurnal cycle until sunrise, when solar PV resources would again start
15 delivering power to the grid and recharging the discharged electrolyte. During
16 the day, the flow battery's virtually instantaneous response capabilities allow for
17 load leveling of daily power fluctuations, providing a constant and even source
18 of energy to the surrounding area. As dusk approaches and renewable generation
19 begins to fade, flow batteries quickly pick up the slack, discharging stored energy
20 to meet demand.

21
22 Lithium-Ion Batteries (Distributed Energy Storage) in High Density Areas. Solar
23 PV systems at commercial-industrial sites and designated city blocks would be
24 supplemented by battery storage systems designed to provide 2-4 hours of power

¹² Hardin, Mark and Brown, Amanda, "[CPUC Energy Storage Use Case Analysis - Distribution Energy Storage: Distributed Storage Peaker](#)," California Public Utilities Commission -- Energy Storage Proceeding, R.10-12-007.

¹³ Prior flow battery prototypes using toxic electrolyte materials initially made the technology environmentally untenable for consideration by the Academy. However, new methods incorporating zinc redox technology have alleviated those concerns.

(appropriately scaled to meet load requirements) in the event of an outage or to support other areas in the distribution grid. Using advanced grid management software, such “nanogrids” within the Santa Barbara ENA will also be able to combine their aggregate storage to collectively act as a “virtual peaker” plant to supplement utility-scale storage during high load periods, for daily ramping requirements or to provide extended grid support to other affected areas during outages.¹⁴

Demand Response/Energy Efficiency Programs (Peak and System Load Mitigation). Every credible energy system must develop efficiency and demand response programs, which serve to reduce overall and peak system loads. SCE should be required to procure a diverse program set of Demand Response and Energy Efficiency resources to help close any gap between projected peak loads and the emerging distributed energy system.

Q: How would you implement this proposed distributed resource plan within the scope of this proceeding?

A: First and foremost, local capacity must be developed in an amount that exceeds whatever shortage would be created from a failure of the primary transmission line. As the IOU responsible for the Moorpark Sub-Area, SCE should be required to reconcile existing and anticipated capacity (both before and following completion of the sub-transmission line upgrade) with the CAISO’s 2016 projected peak load of 321 MW for the Goleta substation that currently serves as the transmission-distribution nexus point for the Santa Barbara ENA.

Once SCE has conducted a transparent analysis that accurately quantifies the shortage resulting from a transmission failure, the Commission should authorize

¹⁴ Hardin and Brown, “[CPUC Energy Storage Use Case Analysis - Distribution Energy Storage: Distributed Storage Peaker](#),” *supra*.

1 an comprehensive feasibility study that would include a requirement for SCE to
2 develop a detailed recommendation regarding the optimal set of Preferred
3 Resources (distributed generation, storage, and/or load reduction through demand
4 response and energy efficiency measures) to address the shortfall.
5 Following completion of the foregoing feasibility study, an accelerated RFO
6 process, similar in nature to SCE's Preferred Resources Pilot Project recently
7 initiated for Orange County, would be completed on an expedited basis and
8 contracts negotiated and approved on a schedule similar to the Orange County
9 PRP.¹⁵

10
11 Subject to completion of the foregoing measures, the Academy believes that
12 initial procurements should involve the development of utility-scale fuel cell
13 and/or battery plants at various substation locations. Appropriately sized fuel
14 cell plants would be installed at substations located near natural gas and biogas
15 sources such as wastewater treatment facilities and landfills. Within the Santa
16 Barbara ENA, these locations include the following facilities:

17
18 Tajiguas Landfill. The landfill facility currently processes enough biogas
19 from landfill emissions to generate approximately three megawatts (3 MW)
20 of power using an obsolete diesel reciprocal engine. Santa Barbara County
21 is also developing a Resource Recovery Project at the landfill to add an
22 additional amount of biogas to generate 1+ megawatt of power (as currently
23 delivered by the diesel engine), for an increase in volume of approximately
24 33% over current levels. The Academy believes that this biogas resource
25 would be better utilized in a fuel cell system, which would not only
26 generate electricity at an efficiency rate of ~47% (increased to ~80%
27 through CHP conversion), but would also produce a syngas that can be

¹⁵ SCE, "[Preferred Resources Pilot](#)," June 2014. *See also*, "[SCE's Preferred Resources Pilot \("PRP"\)](#)," November 6, 2013 and "[SCE PRP RFO Schedule](#)."

1 filtered into a pure hydrogen byproduct, to be used either by the fuel cells
2 to generate additional carbon-free electricity, or stored and sold as a
3 secondary revenue source to local refueling stations for advanced clean fuel
4 vehicles that are scheduled to come on-line by the end of 2015.

5
6 Depending on the relative efficiency rate of the engine currently operating
7 at the landfill, the Academy believes that this new facility at the landfill site
8 can increase energy production by at least 25%. It should also be noted that
9 there are many south-facing hillsides located adjacent to the landfill site
10 that could serve as utility-scale community solar projects to generate
11 additional renewable energy to the Santa Barbara ENA.

12
13 Goleta Wastewater Treatment Plant (“WWTP”). Subject to the volume of
14 biogas produced at the plant, a 1.4 or 2.8 MW fuel cell plant could be
15 installed, with the heat discharge from the fuel cells used to heat the
16 digester units at the wastewater treatment plant. In addition to carbon-
17 neutral energy, which could be delivered to the University of California,
18 Santa Barbara campus in furtherance of their 2025 mandate, hydrogen by-
19 product would also be produced and either sold to refueling stations for
20 secondary revenue or used by the fuel cells to produce more clean energy.
21 To the extent there is insufficient biogas, the fuel cells could also use
22 conventional natural gas to deliver power to the area until such time as a
23 more robust hydrogen delivery infrastructure is developed in California.

24
25 El Estero WWTP / Charles Meyer Desalination Plant. An appropriately
26 scaled fuel cell plant would be located at the wastewater treatment plant in
27 the same manner as at the Goleta WWTP. As discussed above, energy
28 from the fuel cell plant would be primarily used to power the desalination
29 plant, but would be also available on a standby basis for dispatch to the

1 distribution and/or transmission grid when needed. Because power would
2 always be needed to operate the desalination plant, deliverability of this
3 energy would only be limited by the ability to quickly switch the power
4 output of the fuel cells from the plant to the grid and back again. In this
5 unique arrangement, baseload generation by fuel cells can be used in a
6 flexible, dispatchable manner.

7
8 Other Substations. Depending on certain criteria, either fuel cells or flow
9 batteries would be located at all substation sites. For substations with
10 access to natural gas and biogas, fuel cells offer a clean, quiet source of
11 energy, while also providing heat and hydrogen byproducts for direct use or
12 for conversion into surplus energy for storage and/or sale to refueling
13 stations for hydrogen-powered vehicles.

14
15 One substation with locational features meriting the application of both
16 technologies is located in downtown Santa Barbara. This substation could
17 potentially access vast amounts of solar energy from solar PV on
18 commercial, industrial and retail rooftops and parking lots located within
19 the 800-acre area comprised of downtown Santa Barbara and adjacent areas
20 zoned for commercial, industrial and retail (“CIR”) use (collectively, the
21 “SBCIR”).

22
23 Applying a conservative metric of 100,000 square feet (100K SF) for every
24 megawatt (MW) of electricity using solar panels¹⁶ with a 12% efficiency

¹⁶ The standard solar panel on the market today is sized at 3 feet by 5 feet, or 15 sq. ft., and produces about 260 watts. Thus, 100,000 sq. ft. could theoretically accommodate 1,733 kW of solar panels. Discounting that amount of generation by the standard factor of 15% to account for the conversation of DC solar generation into AC power for use on the grid, that leaves as much as 1,473 kW of AC power that could be generated in an area of 100,000 sq. ft. Thus, the 1 MW per 100,000 sq. ft. number being used in my subsequent calculations significantly understates the amount of electricity that could be generated by solar PV panels covering that amount of space.

1 rating¹⁷, and assuming 50% of the SBCIR contains rooftop, parking and
2 others surface areas capable of solar PV development, the energy capacity
3 of the SBCIR can be roughly estimated at varying penetrations of 25%
4 (43.67 MW), 35% (61.14 MW), 50% (87.35 MW) and 65% (113.55 MW).
5 Attached as Exhibit C are digital photos of the SBCIR and selected test
6 sites, along with calculations used to estimate available solar capacity.
7

8 Given the population density and diverse energy usage in the SBCIR, it
9 would be advisable to deploy fuel cell, flow battery and electrolysis
10 capacity and features to manage the large volumes of energy generated
11 once solar PV development in the SBCIR reaches a saturation point.
12 Although these modular technologies will not require immediate
13 installation of the entire projected capacity, space should be allocated so
14 that additional units can be added as solar PV capacity reaches targeted
15 milestones. Initially, while solar PV development is still low, an emphasis
16 on developing flow battery capacity will allow the SBCIR to store whatever
17 surplus renewable is generated for use at night. Once surplus energy
18 exceeds maximum flow battery capacity based on forecast nightly load
19 requirements, then such energy can be diverted to other areas within and
20 outside the Santa Barbara ENA or used for electrolysis of wastewater into
21 hydrogen as a long-term storage reserve or for sale to local HFC vehicle
22 refueling stations.
23

24 For substations located adjacent to south-facing hillsides, a flow battery
25 would be best for short-term storage and use within the 24-hour diurnal
26 cycle. Such substations located near potential renewable energy resources
27 include the, Goleta and San Marcos substations, which are located adjacent

¹⁷ See, Energy.gov, “[Installing and Maintaining a Home Solar Electric System](#),” July 2, 2012.

to south-facing hillsides that could be developed as Solar Community Projects for the generation of utility-scale energy. Attached as Exhibit D are digital images of the area surrounding these substations, with areas of potential solar development and possible flow battery installation sites indicated thereon.

In summary, the Academy proposes that for this proceeding, the Commission should direct SCE to initiate an RFO to procure the following energy projects in lieu of SCE's proposed refurbishment of the 54 MW Ellwood peaker plant:

<u>Preferred Resource Type</u>	<u>Site Location</u>	<u>MW</u>
PV with Battery Storage	Large CIR Rooftops/Parking Areas	75.0
Fuel Cell Plants	Ellwood/Landfill/WWTP/Desal Sites	42.0
1.8/3.6/7.2 MW Flow Battery Plants	Substation Locations	18.0
Energy Efficiency / Demand Response	Throughout SB ENA	<u>15.0</u>
Total Procurement		<u>150.0</u>

V. THE ACADEMY'S BETTER ALTERNATIVE PROJECT IS MORE COST EFFECTIVE THAN SCE'S PROPOSED GAS TURBINES

Q: Can these Preferred Resources be procured on a cost-effective basis?

A: Yes. The cost of installing Solar PV panels on commercial and industrial sites has plummeted in recent years and now has achieved parity with gas-fired peaker plants on a levelized cost of energy ("LCOE") basis.¹⁸ Likewise, energy efficiency and demand response programs have been proven effective in

¹⁸ See, Lazard Ltd., [Lazard's Levelized Cost of Energy Analysis — Version 8.0](#), Sept. 2014, pp. 2-4.

1 reducing peak and overall loads on a per-dollar basis. Fuel cell and flow battery
2 technologies, however, are just beginning to offer their products to the energy
3 marketplace and have not yet achieved economies of scale that will lower
4 production costs such that they can directly compete with established GFG
5 suppliers on a strictly economic, cost per kilowatt-hour, basis.

6
7 This does not mean, however, that procuring these advanced energy products as
8 part of a distributed resources plan to construct a community-wide microgrid is
9 not a cost effective endeavor, when incorporating various unaccounted-for
10 externalities, including but not limited to (i) the health benefits from avoided fine
11 particulate emissions from the Ellwood Peaker Plant, (ii) the avoided costs of
12 fully upgrading the high-voltage transmission lines to reliably bring enough
13 power to the Santa Barbara ENA, and last but not least, (iii) the extremely high
14 value to the State of California of successfully developing and operating a
15 community microgrid project in an extremely transmission-constrained area.
16 Numerous participants in many hearings before the Commission have called for
17 such a demonstration project in order to begin the transition towards a more
18 reliable and resilient distributed energy system.¹⁹

19
20 Furthermore, as shown below, the LCOE of fuel cells and flow batteries are very
21 competitive with peaker plants whose operation is limited to a few hours each
22 day. Combined together, both technologies offer a feature set that is modular,
23 scalable and more importantly, capable of operating completely carbon-free from
24 renewable sources.
25

¹⁹ Picker, Michael, “[Guidance for Section 769 – Distribution Resource Planning](#),” as attached to the [Assigned Commissioner’s Ruling in CPUC Proceeding R.14-08-013](#), pp. 5-7. *See also*, “[CA CEC PON-14-301: Demonstrating Secure, Reliable Microgrids and Grid-Linked Electric Vehicles to Build Resilient, Low-Carbon Facilities and Communities](#),” [EnergyStorage.org](#).

Q: What are the primary sources of your analysis regarding the comparable LCOE of fuel cells, flow batteries and gas turbine peaker plants?

A: The major reference relied on in developing this analysis is the most recent report prepared by Lazard, a highly respected financial advisory and asset management firm with offices all over the world ("Lazard Report"), regarding its LCOE analysis of conventional and renewable technologies.²⁰ Over the years, the Lazard Report has become a standard reference point within the energy industry and has received extensive and favorable press coverage.²¹ Also incorporated into my analysis is a 2011 study on the added value of fuel cells prepared by the National Fuel Cell Research Center at the University of California, Irvine (the "NFCRC Report").²² The NFCRC Report evaluates fuel cells from a wide range of data, including the additional value from avoided health costs and emissions that were excluded in the Lazard Report. Regarding efficacy of flow batteries, I am relying on a 2014 study comparing the capabilities of flow battery energy storage against gas turbine peaker plants.²³

Q: What is the conclusion of the Lazard Report with respect to the relative cost advantages of fuel cells versus traditional gas peakers?

A: The Lazard Report confirms that in the range of LCOE values provided to various technologies, the highest unsubsidized LCOE value assigned to fuel cells

²⁰ See, Lazard Ltd., [Lazard's Levelized Cost Of Energy Analysis — Version 8.0](#), Sept. 2014. Lazard has been publishing versions of this study since 2008 through its Global Power, Energy & Infrastructure Group. This group is active in all areas of the traditional and alternative energy industries, including regulated utilities, independent power producers, advanced transportation technologies, renewable energy technologies, meters, smart grid and energy efficiency technologies, and infrastructure.

²¹ See, e.g., "[Lazard Releases New Levelized Cost of Energy Analysis](#)," Business Wire, September 18, 2014. See also, coverage of and references to the Lazard Report in *The Financial Times*, the [Institute of Electrical and Electronics Engineers](#) website, and *Energy Industry Today*.

²² National Fuel Cell Research Center, "[Build-Up of Distributed Fuel Cell Value in California: 2011 Update / Background and Methodology](#)," University of California, Irvine, July 24, 2011.

²³ Lyons, Chet, "[Guide To Procurement of Flexible Peaking Capacity: Energy Storage or Combustion Turbines?](#)," Energy Strategies Group, October 7, 2014, p. 14.

1 (\$176) is less than the lowest such value assigned to gas peaker plants (\$179).²⁴
2 Also, when calculating the average unsubsidized LCOE of these technologies
3 based on the ranges provided in the Lazard Report, the average unsubsidized
4 LCOE of fuel cells (\$145.50 = the average of \$115 and \$176) is \$59 lower
5 (28.85%) than the unsubsidized LCOE to build a natural gas peaker plant
6 (\$204.50 = the average of \$179 and \$230) as proposed by SCE in this
7 Application.

8
9 Furthermore, after incorporating the benefit calculations of avoided health costs
10 and emissions provided in the NFCRC Report, the savings for adopting fuel cell
11 technology over a gas peaking plant increases to 55.89%, for a net LCOE of
12 \$90.20/MWh.²⁵

13
14 **Q: Would you please describe some of the key assumptions underlying, and the**
15 **data supporting, this conclusion of the Lazard Report?**

16 **A:** To quote from the Lazard Report itself, "[I]nputs were developed with a leading
17 consulting and engineering firm to the Power & Energy Industry, augmented
18 with Lazard's commercial knowledge where relevant. This study (as well as
19 previous versions) has benefitted from additional input from a wide variety of
20 industry participants."²⁶

21
22 It is important to note that the Lazard Report excludes a number of other
23 important factors that would have produced an even more lopsided LCOE cost
24 advantage for fuel cells over gas turbines. Again, to quote from the report itself:
25

²⁴ Lazard Report, Unsubsidized Levelized Cost of Energy Comparison, at p. 2.

²⁵ See Table A in Attachment B, attached hereto.

²⁶ Lazard Report, Summary Considerations, at p. 19.

1 "Other factors would also have a potentially significant effect on
2 the results contained herein, but have not been examined in the
3 scope of this current analysis. These additional factors, among
4 others, could include: capacity value vs. energy value; *stranded*
5 *costs related to distributed generation* or otherwise; network
6 upgrade, transmission or congestion costs; integration costs; and
7 costs of complying with various environmental regulations (e.g.,
8 carbon emissions offsets, emissions control systems). *The analysis*
9 *also does not address potential social and environmental*
10 *externalities*, including, for example, the social costs and rate
11 consequences for those who cannot afford distribution generation
12 solutions, *as well as the long-term residual and societal*
13 *consequences of various conventional generation technologies that*
14 *are difficult to measure* (e.g., nuclear waste disposal,
15 environmental impacts, etc.)"²⁷ [Emphasis added.]
16

17 **Q: What are some of the other key assumptions used in the Lazard Report that**
18 **yield cost advantages for fuel cells over traditional gas turbines?**

19 **A:** Lazard's assumptions include the following:

- 20 1. Net Facility Output. Lazard's assumption for the output of fuel cell plants is
21 based on a small facility of 2.4MW (with an assumed average capital cost of
22 \$5,650/KW), whereas the assumed size of gas peaking plants are in a range
23 from 103MW to 216MW (with an assumed average capital cost of
24 \$900/KW). However, applying routine economies of scale that have been
25 achieved whenever "beta" technologies have become mass produced, it can
26 reasonably be assumed that the cost/KW of constructing a fuel cell plant of a
27 size similar to the assumed peaker plant (103-216MW) would drastically

²⁷ See, Lazard Report, Introduction, at p. 1.

1 reduce fuel cell capital costs to a range that is more in line with the capital
2 costs associated with constructing a peaker plant.

- 3 2. CO2 Emissions. Both fuel cell and peaker plants are assumed to run on
4 natural gas. While peaker plants are assigned a fixed value of 117
5 lb/MMBtu, Lazard assigns fuel cells a range of 0 to 117 lb/MMBtu,
6 acknowledging that CO2 emissions from a fuel cell facility will ultimately lie
7 somewhere between the two extremes.
- 8 3. Construction Time (Months). Lazard assumes a 3-month construction period
9 for a 2.4MW fuel cell plant and a 35-month construction period for a peaker
10 plant. Confirming this timeline is Fuel Cell Energy's 15MW plant in
11 Bridgeport, CT, which was designed and built within one year.²⁸ While
12 constructing a fuel cell plant equivalent in size to a 103-216MW peaker plant
13 would undoubtedly take longer, most if not all of the additional build-out
14 associated with construction of a larger plant could occur simultaneously,
15 keeping project completion well below the 35-month time period ascribed by
16 Lazard for peaker plants. Thus, there is a significant public benefit in relying
17 on fuel cells and flow batteries, each of which can be constructed on a
18 modular basis, rather than on large gas turbines, because given the local
19 capacity requirements created by the shutdown of the San Onofre Nuclear
20 Power Plant ("SONGS") and numerous "once through cooling" ("OTC")
21 facilities located throughout California, the installation of modular fuel cells
22 and flow batteries will be able to meet that need much more quickly than gas
23 turbines.
- 24 4. Heat Rate (Btu/KWh). Peaker plants are assigned a range of 9,000 to 10,300
25 Btu/KWh, while fuel cell plants operate at a much lower range of 6,600 to
26 7,260 Btu/KWh. Standard designs for stationary fuel cell facilities
27 incorporate combined cooling and/or heating and power ("CCHP") features

28

["Fuel Cell Park Makes Polluted Plot into Clean Energy Exemplar,"](#) Hartford Courant, January 2, 2014.

1 that increase overall efficiency by using the heat created during the catalytic
2 process that takes place within the fuel cell to cogenerate direct heating,
3 cooling (through the use of absorption chillers) and/or electricity.
4

5 **Q: Could the fuel cells analyzed in the Lazard Report run on renewable**
6 **hydrogen rather than on natural gas?**

7 **A:** Yes.
8

9 **Q: How would that work?**

10 **A:** Solar and other forms of renewable energy can be used to electrolyze water
11 (including gray water byproduct from waste treatment facilities) into hydrogen as
12 a feedstock for fuel cell plants. A hybrid power plant utilizing the combination
13 of fuel cells properly modified to run on hydrogen, and a flow battery component
14 able to store surplus renewable energy for dispatchability and phase and voltage
15 regulation services, would be able to provide both baseload and peaking
16 functions to address grid load fluctuations relying entirely on electrons generated
17 from renewable resources. This flexible ability to transition to hydrogen is
18 unique to fuel cell technology and is lost if conventional gas-fired technology is
19 chosen to address grid fluctuations.
20

21 **Q: You stated that the Lazard Report excluded from its analysis a**
22 **consideration of various societal benefits, which would tilt their analysis**
23 **even further in favor of fuel cells over conventional gas turbines. Is there a**
24 **way to take such other factors into account?**

25 **A:** Yes.

26 **Q: How would that be done?**

27 **A:** As noted above, the analysis in the Lazard Report does not address “long-term
28 residual and societal consequences of various conventional generation
29 technologies that are difficult to measure.” However, the NFCRC Report

1 aggregated the various benefits associated with fuel cell technology to calculate
2 the additional value that can be realized by ratepayers by using fuel cells as
3 opposed to conventional gas-fired facilities. Averaging the range of values from
4 health benefits and avoided emissions (CO₂, NO_x, SO_x, VOC, PM₁₀ and
5 PM_{2.5}) associated with the use of fuel cells that is provided in the NFCRC
6 Report,²⁹ I calculated the additional fuel cell value from these benefits and found
7 that in a scenario with a fuel cell plant operating on natural gas and using CCHP
8 efficiency measures during 75% of its operations, the average estimated benefit
9 (or cost reduction) from avoided health costs and emission was \$55.30/MWh.
10 Subtracting this estimated benefit from Lazard's average LCOE of \$145.50, the
11 net cost of using fuel cells was \$90.20/MWh, which is over 126% less than the
12 \$204.50/MWh average LCOE assigned to gas peaker plants in the Lazard
13 Report.³⁰

14 15 **VI. OTHER ENVIRONMENTAL BENEFITS OF THE ACADEMY'S** 16 **DISTRIBUTED ALTERNATIVE PROJECT**

17
18 **Q: Are there other economic and environmental benefits of using fuel cells and**
19 **batteries as opposed to conventional gas-fired turbines?**

20 **A:** There certainly are. Such benefits include the following:

- 21 a. Flexibility to Further Reduce GHG Emissions Using Renewable Feedstocks
22 (Hydrogen and Biofuels). Over its 25- to 30-year lifespan, a natural gas
23 peaking plant will operate primarily on one type of fuel: natural gas extracted
24 using fracking operations that emit methane (a greenhouse gas many
25 multiples of times more potent than CO₂ on initial release), consume precious
26 water supplies and rely on a mixture of chemicals that invariably enters our

²⁹ NFCRC Report, at p. 4.

³⁰ See Table B in Attachment B, attached hereto.

1 groundwater reserves. By contrast, developing fuel cell facilities in order to
2 meet the needs that traditional gas turbines can provide, leaves the door open
3 for a transition to 100% renewable fuel in the form of hydrogen produced
4 from renewable sources and gray water or biogas generated from waste
5 treatment facilities. Combined with CCHP co-generation from generated
6 heat, fuel cell plants offer the highest electrical efficiency of any comparable
7 system, resulting in more efficient fuel use and reduced carbon signature with
8 the lowest environmental impact of any power generation system using
9 similar fuels.

10 b. Modularity Creates Ability to Provide Both Baseload and Peaking Services.

11 Capable of using natural gas, renewable biogas and (when properly modified)
12 hydrogen feedstocks, a fuel cell plant is superior to conventional gas peaking
13 facilities in that a fuel cell plant can be operated as a source of baseload
14 power, or in tandem with battery facilities that can serve as phase/voltage
15 regulators to level energy fluctuations and address peaking concerns during
16 the late afternoon/early evening hours. Such a potent combination
17 dramatically enhances the ability of distributed generation and storage to
18 balance renewable generation within microgrid systems in a manner far
19 superior to large, noisy gas turbine peaker plants that emit hazardous
20 particulates to the surrounding community.

21 c. Greater Reliability and Lower Maintenance Costs. Due to the
22 electrochemical nature of both the fuel cell and flow battery power generating
23 process which involves fewer moving parts, a hybrid fuel cell/flow battery
24 facility is more durable, reliable and can be maintained and operated with less
25 oversight than traditional gas-fired facilities.

26 d. Modularity, Small Footprint and Quiet Acoustics of Fuel Cell and Battery
27 Plants Allow for Both Centralized and Distributed Deployment. Unlike gas-
28 fired facilities, whose loud acoustic signature requires either development in
29 sparsely populated areas or limited operating hours, the compact design and

1 extremely quiet acoustics of fuel cell and battery plants allows for siting at or
2 near the point of use in densely populated areas. These non-intrusive
3 characteristics allow fuel cell and battery systems to be sited and installed in a
4 relatively short period of time, and the costs associated with long lead times
5 for siting, permitting and construction are largely avoided. Low emissions
6 and quiet operation also mean that fuel cell and flow battery systems can be
7 rapidly deployed with little to no “NIMBY” opposition from the local
8 community.

- 9 e. Co-Production of Hydrogen. Fuel Cell Plants using biogas or natural gas
10 feedstocks emit a syngas effluent containing a hydrogen component that can
11 be extracted and stored for re-use during off-peak generation periods (thereby
12 further increasing fuel cell efficiencies) or sold to refueling stations as a
13 secondary revenue stream.

14
15 **Q: Coming back to the subject of carbon, are there social costs that have**
16 **traditionally not been valued but that should be imputed to facilities like**
17 **gas-fired peakers?**

18 **A:** Yes. The Fact Sheet issued by the U.S. Environmental Protection Agency
19 ("EPA") on the Social Cost of Carbon ("SCC") acknowledges that “[t]he SCC is
20 meant to be a comprehensive estimate of climate change damages and includes,
21 among other things, changes in net agricultural productivity, human health, and
22 property damages from increased flood risk. However, it does not currently
23 include all important damages. As noted by the IPCC Fourth Assessment
24 Report, *it is 'very likely that [the SCC] underestimates' the damages* [emphasis
25 added]. The models used to develop SCC estimates do not currently include all
26 of the important physical, ecological, and economic impacts of climate change
27 recognized in the climate change literature because of a lack of precise
28 information on the nature of damages and because the science incorporated into

these models naturally lags behind the most recent research. Nonetheless, the SCC is a useful measure to assess the benefits of CO2 reductions."³¹

Q: Given the "lack of precise information on the nature of damages," is it still possible to attempt to quantify the benefits of CO2 reduction?

A: Yes. EPA's SCC Fact Sheet does include four SCC estimates for use in regulatory analyses. Each of these estimates relies on a different set of assumptions and results in projected SCC emissions on a 5-year basis for 35 years starting in 2015 and ending in 2050. Ranging from most conservative to aggressive, these estimates are: (1) 5% Discount Rate Assumed - \$12/ton for 2015, rising to \$28/ton in 2050; (2) 3% Discount Rate Assumed - \$39/ton for 2015³², rising to \$79/ton in 2050; (3) 2.5% Discount Rate Assumed - \$58/ton in 2015, rising to \$104/ton in 2050; and (4) 95th Percentile with a 3% Discount Rate - \$109/ton in 2015, rising to \$235/ton in 2050.

Q: Can you explain why the carbon prices seen to date in California have been hovering at the very bottom of this range?

A: Yes. The EPA's SCC Workshops in 2011 and 2012 established this range of mostly conservative, industry-based metrics and, as indicated in carbon price data provided by the California Carbon Dashboard,³³ the "market" soon adopted the cheapest valuation offered by the EPA following their publication as indicated by the following price points for California Carbon Allowance Futures: High Price - \$23.75 at 9/7/2011; End of 2011/2012/2013 - \$15.50/\$14.75/\$12.05; and 2014 – Price ranges from \$11.66 to \$12.55; Current (4/6/15) - \$12.63.

³¹ US EPA, [Fact Sheet: Social Cost of Carbon](#), November, 2013, at p. 1.

³² It is worth noting that the U.S. Office of Management and Budget has issued guidance recommending a CO2 price of \$37/ton.

³³ Climate Policy Initiative, [California Carbon Dashboard](#).

Q: In comparing the costs of gas turbines burning natural gas, in competition with flow batteries that can store large quantities of surplus renewable energy during peak periods, and fuel cells that can accommodate hydrogen generated from renewable resources as a feedstock, what price should this Commission adopt in this proceeding to reflect the social cost of carbon?

A: When EPA established the initial metrics for SCC in 2011, the perceived pace of climate change was much more moderate, allowing for adoption of very conservative projections regarding the increase in carbon emissions. However, in the intervening years, estimates on the rate of climate change have increased drastically, and the time window for mitigation/remediation has decreased proportionately. This scientific evolution, that has consistently confirmed accelerating rates of climate change, therefore necessitates the adoption of a “worst case” pricing scenario such as the EPA's “95th Percentile” model.³⁴

Employing this model, which is eminently reasonable in light of our growing realization concerning the true cost associated with climate change, it is inconceivable that the gas turbines proposed in this Application would compare favorably to fuel cells when all costs are taken into account. This result is further validated when adding the ability of fuel cells to transition to carbon-free feedstocks such as hydrogen, electrolyzed from renewable resources as California's hydrogen infrastructure is developed, as mandated under SB 1505.³⁵ Under these circumstances, and taking into account the inherent price volatility of a finite resource such as natural gas, it is reasonable to foresee that the cost per MWh of power generated by the proposed gas turbines could eventually be two or even three times as expensive as power generated by fuel cells using hydrogen

³⁴ Shindell, Drew, J., Climatic Change, “[The Social Cost of Atmospheric Release](#),” Springer Netherlands, February, 2015.

³⁵ California Environmental Protection Agency | Air Resources Board, “[Facts About Environmental and Energy Standards for Hydrogen Production \(SB 1505\)](#),” April 27, 2010.

1 made from renewable resources. In a study just released this March, the Union
2 of Concerned Scientists confirmed the existence of such a dynamic:

3
4 “Many experts believe that low natural gas prices are not sustainable over
5 the long term. For example, the U.S. Energy Information Administration’s
6 (EIA) Annual Energy Outlook projects that spot prices will significantly
7 increase from the recent low point of \$2.75 per MMBtu in 2012 to \$6.03
8 per MMBtu in 2030 and \$7.65 per MMBtu in 2040 (EIA 2014c). Factors
9 that contribute to upward pressure on prices and the risk of price volatility
10 include uncertain available supply and potentially increasing demand for
11 natural gas from electric utilities, other competing domestic users, and
12 exporters.”³⁶

13
14 It cannot be overstated that the cost of natural gas is highly volatile. In addition
15 to the factors listed above, today's "low" gas prices are, in large measure, the
16 direct result of the dramatic increase in domestic natural gas supplies attributable
17 to the broad deployment of hydraulic fracturing ("fracking") processes.
18 However, "fracking" has come under close scrutiny due to its serious potential
19 adverse environmental impacts and, as a result, has become subjected to
20 strenuous political opposition in many jurisdictions. New York State has already
21 imposed serious restrictions on "fracking," and local restrictions on "fracking"
22 have been passed in 26 states.³⁷ To the extent that natural gas production is
23 negatively impacted as a result of this broad-based popular movement, natural
24 gas prices WILL go up.

³⁶ Union of Concerned Scientists, [“The Natural Gas Gamble: A Risky Bet on America’s Clean Energy Future,”](#) March 2015, “Price Volatility,” pp. 12-14, Excerpt: p. 14.

³⁷ [“Local Actions Against Fracking – Passed Measures,”](#) Food and Water Watch, 2015.

1 **Q: How does the issue of risk play into how the Commission should consider**
2 **the social cost of carbon in this case?**

3 **A:** This question has been addressed by a number of eminent scholars. The most
4 enlightening discussion of the relationship of risk to the SCC is by Dr. Mark
5 Trexler, a well-known expert on climate change mitigation who currently
6 “specializes in corporate perceptions of climate change risk and how they
7 respond to the uncertainties surrounding climate change and climate policy.”³⁸

8 Dr. Trexler opined as follows:

9 “The topic of risk is critical, and this is where inconsistencies in how
10 we think about SCC risk and other risks become most
11 obvious. Offshore oil platforms in the North Atlantic are NOT
12 designed to have a 50% chance of withstanding ocean conditions for
13 the next 100 years; instead, they are designed to withstand one-in-
14 10,000 year events. At a more personal level, virtually all of us buy
15 fire insurance for our homes. On average, however, very few of our
16 houses will burn down (the probability is so low as to be roundable
17 to zero). So when we think about risk we’re not thinking about
18 ‘averages.’ When the OMB uses an “average” SCC value of
19 \$35/ton, it’s being risk-neutral, not risk-averse. If we want to
20 address climate change, wouldn’t we want to implement an SCC
21 value that would have more than a 50% chance of getting it right?
22 Based on the OMB’s own updated SCC estimates, selecting an SCC
23 with a 95% chance of getting it right would mean a \$90 SCC today,
24 growing to more than \$200 in 2050. That’s a game changer by

³⁸

Climatographer’s Blog, [About Mark C. Trexler](#).

1 anyone's measure, and many observers would argue even that figure
2 is too low due to inadequately quantified climate risks.”³⁹
3

4 **Q: Based on the foregoing analysis, what conclusions should the Commission**
5 **draw?**

6 **A:** The Lazard Report confirms that the average LCOE from a fuel cell plant on an
7 unsubsidized basis is \$145.50, or 28.85% less than the average LCOE of \$204.50
8 to build a natural gas peaking plant. When average benefits of avoided health
9 costs and emissions are included, the savings for adopting fuel cell technology
10 over a gas peaking plant increases to 55.89%, for a net LCOE of \$90.20/MWh.
11

12 On a megawatt-hour basis, the calculated average CO2 emissions in the NFCRC
13 Report equals \$12.95, a figure slightly above the most conservative SCC model
14 offered by the EPA using a risk-neutral cost-benefit analysis. However, the EPA
15 has admitted in its own Fact Sheet that the current cost-benefit model for
16 calculating SCC underestimates the true costs of CO2. Thus, a model needs to
17 be adopted that incorporates society's aversion to the risks posed by climate
18 change and its willingness to accept higher CO2 costs to produce a certainty of
19 significant GHG reductions.
20

21 Currently, the “95th Percentile” model incorporating a 3% discount rate mostly
22 closely matches that need. This model places a much higher value on avoided
23 CO2 emissions than previously used, and will inevitably drive the comparative
24 net LCOE for fuel cells and flow batteries, on an MWh basis, to a point that is
25 dramatically lower than the anticipated cost per MWh from the gas turbines
26 proposed in this Application.

³⁹ Trexler, Mark, “[What's Missing From the OMB's New Social Cost of Carbon? Risk Aversion](#),” Climatographers, June 20, 2013. See also, Kaufman, Noah, “[Why is Risk Aversion Unaccounted for in Environmental Policy Evaluations?](#),” NERA Economic Consulting, July 9, 2014.

1
2 **Q: Are there additional steps that the Commission should take to explore the**
3 **viability of promising clean energy technologies such as fuel cells?**

4 **A:** Yes. I believe that there is ample time available for the Commission to conduct
5 an comprehensive comparative study of fuel cells and flow batteries as flexible,
6 adaptable technologies that can operate at a level of performance equivalent or
7 superior to natural gas peaker plants, while also retaining the ability to fully
8 integrate with a new, distributed carbon-free energy system based primarily on
9 renewable energy.

10
11 Although the World Business Academy does not expect the Commission to
12 conduct a holistic study of the relative "big picture" economics of fuel cells and
13 batteries versus traditional gas-fired resources in the context of this proceeding,
14 the Academy does urge the Commission to conduct or commission such a study
15 in the near future, either as part of the Commission's Long-Term Procurement
16 Planning process or as part of a larger inter-agency effort to address California's
17 clean energy goals. With such a study in hand, the Commission will be in a
18 much stronger position to direct its jurisdictional utilities to put an end to the
19 ongoing, environmentally harmful practice of proposing the construction of new
20 fossil-fired plants to meet system needs for local capacity and instead look for
21 combinations of preferred resources to facilitate the integration of ever-
22 increasing amounts of variable renewable generation.

23
24 Furthermore, substituting fuel cells and batteries for conventional gas turbines
25 will ultimately create a distinct pathway for the development of a renewable
26 hydrogen economy, and creates additional demand for "green" hydrogen in
27 tandem with the emerging market for fuel cell electric cars ("FCEVs") currently
28 under development in California. As a secondary FCEV market develops in
29 California, the sale of renewable hydrogen to refueling stations (as mandated by

1 SB 1505 to equal one-third of all hydrogen produced for that purpose⁴⁰) will
2 increase demand and build economies of scale that will lower the cost of
3 hydrogen. As the price of hydrogen becomes more affordable, fuel cell plants can
4 incrementally transition to 100% carbon-free operation.

5
6 If the Commission allows the proposed peaker facilities to move forward without
7 serious consideration of alternative technologies that are environmentally
8 superior in all respects and that will ultimately be a better deal for ratepayers, it
9 will have sentenced Ellwood and Oxnard citizens to at least 20 years of living
10 next to large, noisy, highly visible centralized plants that have no prospects for
11 significantly reducing carbon and particulate emissions during its useful lifespan.

12
13 The Commission therefore needs to recognize that by choosing fuel cell
14 technology and various Preferred Resources to meet the identified LCR need, it
15 will dramatically enhance the ability of the citizens living within the Moorpark
16 Sub-Area to locate distributed power generated by quiet fuel cell and battery
17 plants, housed in unobtrusive structures arranged in a wide variety of
18 configurations that maximize energy reliability and resilience while also yielding
19 these facilities virtually invisible to the surrounding community.

20
21 Moreover, such a choice will significantly expand the flexibility of SCE to meet
22 its local reliability needs in a much more flexible manner than would be the case
23 if it is forced to rely for 20+ years of traditional gas peakers. Rather, by
24 strategically distributing some or all of the power infrastructure, which a switch
25 to fuel cells and batteries to meet the identified LCR need will facilitate, SCE
26 and its PPTA partner will greatly enhance the resilience and reliability of the

40

California Environmental Protection Agency | Air Resources Board, [“Facts About Environmental and Energy Standards for Hydrogen Production \(SB 1505\),”](#) April 27, 2010.

1 local power grid while taking up the historic mantle of leading the state to the
2 renewable energy economy of the future.

3
4 **Q: Does this conclude your prepared testimony?**

5 **A:** Yes, it does.

ATTACHMENT A

***CURRICULUM VITAE* OF ROBERT PERRY DIRECTOR OF ENERGY RESEARCH OF THE WORLD BUSINESS ACADEMY**

Robert Perry

Professional Expertise:

Mr. Perry currently serves as the Director of Energy Research for the World Business Academy, a non-profit business think tank, action incubator and network of business and thought leaders, whose mission is to inspire business to assume responsibility for the whole of society and assist those in business who share our values.

As Director of Energy Research, Mr. Perry is the primary source for research and analytical support services in connection with the Academy's [Safe Energy Project](#), whose objectives are to (1) rid the state of California of nuclear power plants, (2) stand up for ratepayers' interests in proceedings before the California Public Utilities Commission and (3) to introduce and champion a plan for the conversion to 100% renewable energy in California called [The Clean Energy "Moonshot" Project](#), to create a replicable renewable energy model for the world.

In his capacity as Director of Energy Research, Mr. Perry performs a wide range of general, technical and financial research and analysis concerning issues underlying all aspects of the Safe Energy Project, including but not limited to current and emerging energy generation, transmission and distribution, microgrid, and storage systems as they relate to the development of an integrated system of distributed energy capable of operating entirely on renewable energy, either directly or indirectly through a storage medium such as hydrogen.

Prior to his tenure at the World Business Academy, Mr. Perry served as the Executive Assistant to the CEO of Ameristar Casinos, a publicly-held company operating a chain of regional casinos. As Executive Assistant, Mr. Perry performed a wide range of analytical functions, including but not limited to preparation of annual regulatory filings with state gaming authorities, distribution of a daily report summarizing industry media and financial analysis, review and analysis of internal financial reports and periodic securities filings, and weekly audit control analysis reports.

Prior to serving at Ameristar, Mr. Perry worked for 20 years with a variety of law firms as a corporate, securities and real estate legal assistant. During that time, Mr. Perry performed due diligence research and drafted primary and ancillary documents relating to wide range of business transactions (mergers and acquisitions, real estate portfolio development and management, venture capital financings and initial/secondary private and public offerings). A subset of these skills also included the preparation and review of budgetary reports, projections, market analyses and investment materials, including all relevant compliance documentation required on state and federal levels.

Education:

Paralegal Certification in Corporate, Securities and Real Estate Specialties, University of San Diego, 1983

Bachelor of Arts Degree in Liberal Studies, with emphases in History, Music and Political Science, University of California, Santa Barbara, 1983

ATTACHMENT B

TABLES

TABLE A

LCOE COST VARIANCES USING LAZARD / NFCRC DATA

	Unsubsidized LCOE			% Variance (Cost Reduction v. Add'l Cost)		
	<u>Low</u>	<u>High</u>	<u>Ave.</u>	<u>Fuel Cell</u>	<u>Adj. Fuel Cell</u>	<u>Gas Peaking</u>
Fuel Cell	115.00	176.00	145.50	0.00%	-61.31%	28.85%
Fuel Cell (Adjusted)*	89.30	91.10	90.20	38.01%	0.00%	55.89%
Gas Peaking	179.00	230.00	204.50	-40.55%	-126.72%	0.00%

* Avoided Health Cost / Emissions from 100% NG / 75% CCHP Operations per NFCRC Report

TABLE B



COST REDUCTIONS FOR HEALTH BENEFITS AND AVOIDED EMISSIONS

	<u>Low</u>	<u>High</u>	<u>Ave.</u>
Fuel Cell Unsubsidized LCOE (\$/MWh) (Per Lazard Report)	\$115.00	\$176.00	\$145.50
<u>Operational Assumptions:</u>			
100% NG / 75% CCHP			
<u>NFCRC Benefit Calculations</u>			
Health Benefits	2.14	2.18	2.16
Avoided CO2 Emissions	0.16	2.43	1.30
Avoided Other Emissions	0.27	3.88	2.08
Total (¢/KWh)	2.57	8.49	5.53
<i>Converted to:</i>			
Total (\$/MWh*)	\$25.70	\$84.90	\$55.30
 Adjusted Unsubsidized LCOE (\$/MWh)	 <u>\$89.30</u>	 <u>\$91.10</u>	 <u>\$90.20</u>

* = (¢/KWh x 1000 KWh/MWh) ÷ 100 ¢/\$

ATTACHMENT C

AERIAL PHOTOS AND ESTIMATES REGARDING SOLAR PV CAPACITY





ATTACHMENT D

**AERIAL PHOTOS AND ESTIMATES
REGARDING POTENTIAL COMMUNITY SOLAR PROJECTS**

